

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Rotarex Fareast Pte Ltd	Client ID	106794
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS 5062-2016 : Fire protection for mobile and transportable equipment		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	10/11/2020	Certification Expiry Date	30/09/2025
Certificate Issue Date	10/11/2020	Certificate Last Update Date	27/11/2020

APPROVED COMPANY/SITE ADDRESS(ES):

10 Ubi Crescent Ubi Techpark lobbyB #04-11 - 408564 Singapore

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: **3087CA48CD6EDB8ACA25862B0071F264**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
024100037	024100037	Rotarex	Gasket / Stainless steel / Ø1/4" / Ø20,6 / ØI 13,8	30/09/2020
026205098	026205098	Rotarex	Nozzle 1 hole for CLS / Stainless steel / G1/8" male / protection cap included	30/09/2020
B07800002	B07800002	Rotarex	FireDETEC sensor tube / Ø6X1 / L100M / Black	30/09/2020
B07800202	B07800202	Rotarex	FireDETEC sensor tube / Ø6X1 / L10M / Black	30/09/2020
B07835026	B07835026	Rotarex	Double ring fitting / straight / Ø8 / G 1/4" male / 316L	30/09/2020
B07835027	B07835027	Rotarex	Double ring fitting / straight / Ø8 / 316L	30/09/2020
B07835029	B07835029	Rotarex	Double ring fitting / tee / Ø8 / 316L	30/09/2020
B07835030	B07835030	Rotarex	Double ring fitting / tee / Ø8 / R 1/8" female / 316L	30/09/2020
B07835031	B07835031	Rotarex	Double ring fitting / elbow / Ø8 / R 1/8" female / 316L	30/09/2020
B07835047	B07835047	Rotarex	Double ring fitting / straight / Ø8 / R 1/8" female / 316L / nozzle	30/09/2020
B07860006	B07860006	Rotarex	Mounting Bracket for piping/ Ø8/PA6.6	30/09/2020
B09023000	B09023000	Rotarex	Compact Line / pneumatic actuation / TPED / 12L	30/09/2020
B09024000	B09024000	Rotarex	Compact Line / pneumatic actuation / TPED / 4L	30/09/2020
B09025000	B09025000	Rotarex	Compact Line / pneumatic actuation / TPED / 7L	30/09/2020
S04420145	S04420145	Rotarex	End of line / manual actuator / butterfly type	30/09/2020
S07850302	S07850302	Rotarex	Electronic Monitoring Unit / pneumatic actuation / 7V DC to 35V DC / 85dB / IP65	30/09/2020
S20080163	S20080163	Rotarex	RX-FF3 / Fluorine free extinguishing agent	30/09/2020
S22700599	S22700599	Rotarex	Discharge tubing / Stainless steel 316L / Ø8 / 1m	30/09/2020
S22720039	S22720039	Rotarex	Fire suppression hose / MSHA 2G	30/09/2020
S28255048	S28255048	Rotarex	Pressure switch / 9 bar / 1/8" NPT / SPDT	30/09/2020

Comments:

- 1) Compliance applies to Clause 6.3.3.2: Foam water spray,
- 2) To be installed, commissioned and operated as per the manufacturer's manual CLS Owner's manual 15102020.

End of the document



Certification Manager

